



# TUMAKURU CITY CORPORATION, TUMAKURU



Website: [www.tumkurcity.gov.in](http://www.tumkurcity.gov.in)  
E-mail : [itstaff\\_ulb\\_tumkur@yahoo.com](mailto:itstaff_ulb_tumkur@yahoo.com)

Telephone ☎ 2278480. Fax :2275106  
Complaints ☎ : 0816-2272200, 2271200

No:TCC/Health Section/CR- 057 /2025-26

Date:02.05.2025



## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

\*\*\*

It is certified that an inspection headed by Dr.Veerayya kalmath Health Officer Tumakuru City Corporation inspected the Sheshadripuram English School CA Site no 4 Melekote Gangasandra Main Tumakuru -572105 on 20.04.2025 and checked the drinking water test report with sample code: TUM25APR0900 ULR No TC-1484125000000900F Date: 09.04.2025 submitted by the Institution and found that Institution has Potable Drinking water for students and staff of the Sheshadripuram English School and is having provision for running water in the toilets and is maintaining the hygienic sanitation condition in the building & the campus as per the norms prescribed by the Central /state/U.T.Govt.

This Certificate is issued for the year 2025-26

(Dr.Veerayya kalmath)

Health Officer

Tumakuru City Corporation  
Tumakuru

To,  
Sheshadripuram English School  
CA Site no 4 Melekote  
Gangasandra Main  
Tumakuru -572105

2025  
PRINCIPAL

SESHADRIPURAM ENGLISH SCHOOL  
CA-4, Melekote, Veerasagara Layout  
Gangasandra, Tumakuru-572105

For SESHADRIPURAM ENGLISH SCHOOL

Shwetha K.  
MANAGER



# Tumkur District Water Quality Testing Laboratory

TC- 14841

Zilla Panchayath Compound B.H Road Tumkur - 572101, Karnataka.

Email: [rdwsd.wqmsp.tumkurdistrictlab@gmail.com](mailto:rdwsd.wqmsp.tumkurdistrictlab@gmail.com)

## TEST REPORT

Seshadripuram English School, Melekote, Veerasagara Layout, Gangasandra Main Road, Tumkur Tq District.: Tumkur Contact no: Seshadripuram English School.:9686600286, :8105957641				Sample Collected By: Maruthi.C		
				Reference: Sample Receipt Form		
				Sample code:TUM25APR0900		
				ULR No. : TC- 148412500000900F		
				Date of Sample collection:08/04/2025		
				Sample receipt date: 08/04/2025		
				Analysis start date: 09/04/2025		
				Analysis completion date: 09/04/2025		
Report date: 09/04/2025						
Sampling Method: APHA24 <sup>th</sup> Edition						
Sample quantity:1 Liter						
Sample Particulars :Drinking Water						
Sl. No	Test	Test Method	Acceptable Limit IS 10500 :2012	Permissible Limit IS 10500 : 2012 RA-2018	Results	Units
Description: Colourless liquid.						
1.	pH Value at 26.2°C	IS 3025 (Part-11) : 2022	6.5 – 8.5	No relaxation	6.53	-
2.	Electrical Conductivity, at 26.2°C	IS 3025 (Part-14) :2019	-	-	78	µS/cm
3.	Odour	IS 3025 (Part-5 & 6):2018	Agreeable	Agreeable	Agreeable	-
4	Taste	IS 3025 (Part-7 & 8):2023	Agreeable	Agreeable	-	-
5.	Colour	IS 3025 (Part-4) :2023	5	15	<1	Hz
6.	Turbidity	IS 3025 (Part-10) : 2023	1	5	<0.5	NTU
7.	Total Dissolved Solids @ 180°C	IS 3025 (Part-16) : 2023	500	2000	44	mg/l
8.	Alkalinity as CaCO <sub>3</sub>	IS 3025 (Part-23) : 2023	200	600	BDL	mg/l
9.	Total Hardness as CaCO <sub>3</sub>	IS 3025 (Part-21) : 2019	200	600	28	mg/l
10.	Calcium as Ca	IS 3025 (Part-40) : 2024	75	200	9	mg/l
11.	Magnesium as Mg	IS 3025 (Part-46) : ,2023	30	100	BDL	mg/l
12	Chloride as Cl	IS 3025 (Part-32) : 2019	250	1000	14	mg/l
13.	Sulphate as SO <sub>4</sub>	IS 3025 (Part-24/Sec 1) : 2022	200	400	2	mg/l
14.	Fluoride as F, mg/l	APHA 24 th Edition 4500- F D	1	1.5	BDL	mg/l
15.	Nitrate as NO <sub>3</sub> , mg/l	APHA 24th Edition 4500- NO <sub>3</sub> B	45	No relaxation	4.1	mg/l
16.	Iron as Fe, mg/l	IS 3025 (Part-53) : 2024	1	No relaxation	BDL	mg/l
Reviewed & Authorized By						
 Venkatesh .H Technical Manager						

### Note:

- The above results relate only to the sample tested.
- The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- Samples will be discarded after 15 days from the date of report generation.
- Decision rule is applicable as per the procedure mentioned in RDWS/WQMSP/DR-01
- BDL: Below Detectable Limit.

RDWS/WQMSP/TeR/01

**PRINCIPAL**  
 SESHADRIPURAM ENGLISH SCHOOL  
 CA-4, Melekote, Veerasagara Layout  
 Gangasandra, Tumakuru-572105

For SESHADRIPURAM ENGLISH SCHOOL

Page 1 of 1  
  
**MANAGER**